



**COMMUNITY DEVELOPMENT DEPARTMENT**

**Code Administration Division**

**129 North Second Street, 2nd Floor Yakima, Washington 98901**

**(509) 575-6126 • Fax (509) 576-6576**

**codes@yakimawa.gov • www.buildingyakima.com**

**RESIDENTIAL TANK ABANDONMENT**

Where removal of the tank is not necessary, abandonment in place is allowed.

A permit is required; the fee amount is, \$23.86. This permit can be issued to the homeowner or contractor. Work to remove/abandon the tank will be done by the homeowner or a Washington state licensed contractor.

Upon permit issuance, an inspection can be scheduled and a Code Inspector will sign the permit confirming removal or in place abandonment.

Tanks abandoned in place shall be abandoned as follows:

1. Flammable and combustible liquids shall be removed from the tanks and connected piping.
2. The suction, inlet, gauge, vapor return and vapor lines shall be disconnected.
3. The tank shall be filled completely with an inert solid material (sand, pea gravel, concrete slurry or other concrete mixture) approved by the Code Administration.
4. Remaining underground piping shall be capped or plugged.

Note: Abandoning the tank in place, without filling with inert material, is no longer permissible.

The information provided herein shall not be construed to permit violations of any City, State and/or Federal laws.