



- NOTE:**
1. All WORK AND MATERIALS SHALL CONFORM TO THE NATIONAL ELECTRICAL CODE (NEC).
  2. JUNCTION BOX, CONDUIT AND CONSTRUCTION METHODS SHALL BE PER WSDOT - TYPE 1 UNLESS OTHERWISE SPECIFIED AND APPROVED BY THE CITY ENGINEER.
  3. ALL ELECTRICAL CONDUIT SHALL BE A MINIMUM OF 2" DIA. AND MAINTAIN 24" MINIMUM COVER. SWEEPS AND PLAN LOCATION SHALL BE PER POWER COMPANY AND SHALL BE DETAILED ON THE PLANS PRIOR TO APPROVAL.
  4. ALL SERVICE CONNECTIONS WHETHER INDIVIDUAL OR MULTIPLE POLES SHALL BE PEDISTAL MOUNT ONLY. SERVICE CONNECTIONS SHALL NOT BE ALLOWED TO BE ATTACHED TO THE POLE.
  5. POLE, BASE, AND LIGHT FIXTURE AS MANUFACTURED BY HOLOPHANE COMPANY.



**City Of Yakima  
Engineering Division**

129 North Second Street  
Yakima, Washington

City of Yakima - Standard Detail  
**ORNAMENTAL LIGHT**

NOT TO SCALE  
Revision 7-2011

**E2**