



NOTES

1. PROVIDE EXTENSION PIECE WHERE REQUIRED FOR VALVE BOX. (RICH MODEL 044, 12 INCHES HIGH)
2. VALVE SIZE AND ENDS AS SPECIFIED OR INDICATED ON THE PLANS.
3. CONCRETE OR A.C. PAD REQUIRED IN AREAS OUTSIDE OF STREET SURFACE.

W2  
 NTS
 

 WATER VALVE BOX  


---

 City of Yakima – Engineering Division

APPROVED: 11.15.16