



NOTES

1. RESTRAIN MINIMUM OF 70 LF OF PIPE WITH FIELD-LOK GASKETS PRIOR TO BLOW OFF ASSEMBLY.
2. ALL BRASS TO BE NON-LEAD.



City Of Yakima  
Engineering Division

129 North Second Street  
Yakima, Washington

City of Yakima - Standard Detail  
**TYPICAL BLOW OFF ASSEMBLY**

NOT TO SCALE  
Revision 1-2025

W5