



NOTES

1. AIR-VENT PIPING AND ARV TILE TO BE SET BEHIND CURB LINE OR BACK OF SIDEWALK
2. SLOPE TUBING TO PROVIDE CONTINUOUS RISE IN PIPE FROM CORPORATION BALL VALVE TO AIR-VACUUM VALVE.
3. ALL BRASS TO BE NON-LEAD



**City Of Yakima
Engineering Division**

129 North Second Street
Yakima, Washington

City of Yakima - Standard Detail
AIR-VACUUM RELIEF VALVE

W8

NOT TO SCALE
Revision 11-2024