



2023

WATER QUALITY REPORT

Inside this issue:

Introduction and source water education	1
Summary tables, pt.1 and glossary with definitions	2
Summary tables, pt. 2 and a link to a Conservation page.	3
Lead and Copper Rule sample results table .	4

City Of Yakima Water production for 2023

Naches River WTP	2.807 Billion
Airport Well	101.9 Million
Kissel Well	486 Million
Kiwanis Well	94.9 Million
Gardner Well	431.4 Million

Naches River Water Treatment Plant

The City of Yakima is once again pleased to present our annual report on water quality. In addition to the results of our major testing programs, we hope this pamphlet will inform you about your tap water and inspire confidence that the water we all rely on is of the highest quality possible. In pursuit of that goal the Water/Irrigation Division staff is committed to around-the-clock vigilance and service, and we are proud to announce that your tap water meets and exceeds all state and federal requirements.

WHERE YOUR WATER COMES FROM

The Naches River supplies most of Yakima's drinking water. Our diversion is located along Hwy 12 and supplies the Naches River Water Treatment Plant at Rowe Hill. After treatment, water flows by gravity along the highway into town. During times of heavy runoff or when the Plant requires downtime maintenance, we can draw upon our 4 wells. They are located at Kiwanis Park, Kissel Park, Gardner Park, and Yakima Airport. These wells draw from the Ellensburg Aquifer and are also tested regularly.





Every year we take hundreds of samples and analyze them for disinfection byproducts, synthetic and volatile organics, biological, radiological, and inorganic contaminants. The tables below show the most important and frequently requested results for 2023. If you have any questions about these tests or if you would like to know about a substance not listed here you can call the Water Quality Specialist at 509-576-6477.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Microbial Contaminants		Each year 960 samples from the distribution system are collected and analyzed to comply with the Total Coliform Rule (TCR). Coliforms are environmentally ubiquitous bacteria that live in the ground. The presence of coliforms in the water may indicate a leak, a cross-connection, or other problems.				
Name	Units	MCL	MCLG	Number detected	Range low/high	Violation?
Total Coliform	Sample	>5%	0	0	0—100%	No

Disinfection and Disinfection Byproducts		Disinfection Byproducts (DBP's) are formed when the chlorine added as a disinfectant combines with the naturally occurring organic matter (NOM) to form potentially harmful compounds. These compounds are divided into two main groups: Trihalomethanes (THM's) and Haloacetic Acids (HAA5's.)				
Name	Units	MCL / MRDL	Range	2023 Average	Violation?	
Chlorine	mg/L	4.0	0.29-1.84	1.3	No	
TTHM's	ppb	80	9.77—55.3	40.4	No	
HAA5's	ppb	60	5.11—44.9	29.9	No	

Turbidity		Turbidity is a measure of the "cloudiness" of water. High turbidity can indicate poor water quality. Sources of turbidity are generally attributed to soil runoff caused by heavy rain or snowmelt.				
Name	Units	MCL	2023 Average	Range low/high	Violation?	
Turbidity	NTU	TT	0.016	0.01—0.08	No	

Glossary for Tables

< = less than

MCL = Maximum Contaminant Level, the highest level of a contaminant allowed in drinking water.

MCLG = Maximum Contaminant Level Goal, the level of contaminant below which there is no known or expected health risk.

mg/L = milligrams per liter. Equal to ppm.

MRDL = Maximum Residual Disinfectant Level, the highest level of a disinfectant allowed in drinking water.

MRDLG = Maximum Residual Disinfectant Level Goal, the level of drinking water disinfectant below which there is no known or expected health risk.

NTU = Nephelometric Turbidity Unit.

ppm = part per million

ppb = part per billion

TT = Treatment Technique, a required process intended to reduce the level of a contaminant.

Fluoride

Fluoride is added to drinking water to improve dental health. Fluoridation in Yakima began in 2004 after a referendum vote in 2001. For more information about water system fluoridation, please visit the DOH website: http://www.doh.wa.gov/Portals/1/Documents/Pubs/160-021_Fluoridate_Facts.pdf

Name	Units	MCL	MCLG	2023 Average	Range	Violation?
Fluoride	ppm	4.0	2.0	0.65	0.12—1.18	No

Primary Standards

National Primary Drinking Water Regulation primary standards are legally enforceable standards that apply to public water systems. There are more primary standards not included here because they were present in undetectable amounts.

Name	Units	MCL	MCLG	Amount detected	Violation?	Source
Arsenic	ppm	0.01	0	ND	No	Erosion of natural deposits, industrial waste.
Barium	ppm	2	2	0.00375	No	Erosion of natural deposits, industrial waste.
Chromium	ppm	0.1	0.1	ND	No	Erosion of natural deposits, industrial waste.
Nitrate	ppm	10	10	ND	No	Erosion of natural deposits, fertilizer runoff, sewage, and faulty septic systems.
Nitrite	ppm	1	1	0.211	No	Erosion of natural deposits, fertilizer runoff, sewage, and faulty septic systems.
Thallium	ppm	0.002	0.0005	ND	No	Industrial waste.

Secondary Standards

Secondary standards are non-enforceable guidelines regulating contaminants that may have cosmetic or aesthetic effects, such as taste, odor, or staining.

Name	Units	MCL	Amount detected	Name	Units	MCL	Amount Detected
Calcium	mg/L	—	10.2	Manganese	mg/L	0.05	0.00233
Chloride	mg/L	250	5.85	Turbidity	mg/L	—	0.129
Color	units	15	<4	Silver	mg/L	0.1	ND
Conductivity	µmhos/cm	700	118	Sodium	mg/L	—	6.0
Hardness	mg/L	—	33.4	Sulfate	mg/L	250	3.45
Iron	mg/L	0.3	ND	Total Dissolved Solids	mg/L	500	72
Magnesium	mg/L	—	2.04	Zinc	mg/L	5	0.00121

Drought & Conservation Info

We at the City of Yakima strive to provide safe and reliable drinking water year round.

Please visit this link to see how you can help save water this drought season.

<http://www.yakimawa.gov/services/water-irrigation/drought-conservation/>

Water and Health

Some people may be more vulnerable to certain chemical compounds and substances in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA and the Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the **Safe Drinking Water Hotline (800-426-4791)**.

About Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Yakima is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure to lead by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800) 426-4791, or <http://www2.epa.gov/lead>

Questions, Comments, Concerns?

The City of Yakima welcomes your input! The City Council meets on the first and third Tuesday of each month at City Hall Council Chambers. You are encouraged to attend. If you would like to schedule a tour of the Naches River Water Treatment Plant, please call 575-6177. If you would like to talk about this report please call 576-6477.

Lead and Copper Rule

Every three years the City of Yakima is required to analyze water samples from homes determined by the EPA to be most susceptible to lead and copper leaching from pipes and plumbing components. The City of Yakima is very pleased to present the 2021 results of all these analyses here, as it is the most recent data that we have. The element abbreviation for lead is Pb, and copper is Cu. All values are mg/L, or PPM. The Rule sets an Action Level (AL) for lead at 0.015 mg/L and 1.3 mg/L for copper. As you can see, all of these locations from throughout our service area show very low to essentially undetectable amounts of these harmful metals.

	Site 1	Site 8	Site 10	Site 11	Site 14	Site 15	Site 17
Pb	0.0001	0.0003	0.002	0.00014	0.00031	0.0004	0.0001
Cu	0.0498	0.0722	0.015	0.12	0.0746	0.127	0.0882
	Site 18	Site 22	Site 25	Site 26	Site 28	Site 31	Site 32
Pb	0.0002	0.0008	0.0001	0.00013	0.0003	<0.0001	0.0002
Cu	0.0443	0.0124	0.0465	0.0206	0.0384	0.0346	0.0374
	Site 36	Site 38	Site 39	Site 40	Site 41	Site 43	Site 44
Pb	0.00013	0.0003	0.00061	0.0001	0.0001	0.0001	0.0007
Cu	0.0185	0.0342	0.0631	0.0678	0.0484	0.0522	0.0925
	Site 48	Site 49	Site 56	Site 58	Site 60	Site 62	Site 66
Pb	0.0003	0.0003	0.0001	0.00033	0.00049	0.00022	0.00023
Cu	0.0146	0.0891	0.0764	0.0696	0.0222	0.0902	0.0267
	Site 69	Site 81	Site 84				
Pb	0.00016	0.0002	0.00085				
Cu	0.0142	0.126	0.0459				



A big THANK YOU! to all 31 residents that participated in 2021. We will again be testing for Lead and copper in the summer of 2024. We look forward to your continued support. We couldn't do it without your cooperation.